

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 002/2026-2027

Dated: 29/09/2026

It is certified that an inspection team headed by Dr. D. JAGADESH MBBS (Name of Officers with designation) from BMO, GPHC, THIRUVIZHIMILALAI S PHED inspected the SWAMI DAYANANDA VIDYALAYA, MANJAKKUDI (Name & Address of the school) on 29-09-2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no TR/2026/25497 dated 01.07.2026 of TAMILNADU WATER SUPPLY AND DRAINAGE BOARD (PHED Lab) certified that the SWAMI DAYANANDA VIDYALAYA (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till ONE YEAR (01.07.2026 - 30.06.2027)

S. J. S. S.
BLOCK HEALTH SUPERVISOR,
B.H.S.

GOVT. P.H.C. TIRUVIZHIMAZHALAI,
(KODAVASAL BLOCK).

J. Jagadeesh
BLOCK MEDICAL OFFICER,
Govt. Primary Health Centre (Upgraded)
Thiruvizhimizhalai - 609 501.

Signature with Seal :

Name :


Designation :

Name & Address of the Office / Department:

forwards
29/09/2026
District Health Officer,
Thiruvavur.

To SWAMI DAYANANDA VIDYALAYA
MANJAKKUDI, TIRUVARUR - 612603

(Name & Address of the Institution)



Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

TRANSLATION OF THE TAMIL SEAL

Certified that the Tamil words appearing in the official seal affixed on the ANNEXURE – C PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE are translated into English as follows:

Tamil Seal:

“மாவட்ட சுகாதார அலுவலகம், திருவாரூர்”


English Translation:

“DISTRICT HEALTH OFFICE, TIRUVARUR”

I certify that the above is a true and correct English translation of the Tamil words appearing in the official seal.

NOTARY ATTESTATION

Identified / Translated by me and sworn/affirmed before me.



S. KANDASAMY M.A., B.L.
Advocate & Notary Public
Regn. No. 11278 /15
7 H A B. Complex 2nd Floor,
South Main Street,
TIRUVARUR - 610 001,
Tamilnadu.



GOVERNMENT OF TAMIL NADU

DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

பொது சுகாதாரம் மற்றும் நோய்த் தடுப்பு மருந்துத்துறை

SELF DECLARED SANITATION CERTIFICATE

(Issued under G.O.(Ms)No. 276 of Health and Family Welfare (AB2) Department dated

23.09.2024 on the basis of affidavit by the applicant)

Certificate Number : TN00126TVR49094

Issued Date : 22-08-2026

Organization Type : Educational Institutions

Expiry Date : 21-08-2027


Name of the Organization : SWAMI DAYANANDA VIDYALAYA

**Address : SWAMI DAYANANDA CAMKPUS, MANJAKKUDI,
TIRUVARUR**

I, **RUKMANI** owner/manager of the **SWAMI DAYANANDA VIDYALAYA** functioning as **Educational Institutions** located at **Arasur in Thiruvavarur** district hereby declare that

- This Self-Declared Sanitation certificate is valid from **22-08-2026** to **21-08-2027** and will be renewed every year prior to the expiry of the current certificate with updated information.
- Our premises can accommodate **1500** people/pupils and has **16** urinals and **66** toilets which is proportionate to the number of users as per government norms.
- **10** Sanitation workers are deployed to clean the entire premises including Toilets, Common Area Spaces, etc., at regular intervals and proper record is maintained.
- The waste generated on our premises is properly processed and disposed of as per Solid Waste management Rules, 2016.
- There is no potential mosquito breeding area on the premises.
- The premises have adequate drinking water fountains on each floor of the premises.
- The self-declared certificate is displayed prominently on the premises along with the protocol

The Government reserves the right to inspect at any point of time and cause for rectification or cancel or suspend the certificate and take legal action if any conditions are violated.



Signature of the Owner/Manager



(அ) TN00126TVR49094 என்ற தனிப்பட்ட சான்றிதழ் எண்ணை

<https://www.tnsevai.tn.gov.in/edistrict/CheckStatus/Certificate/> ல் உள்ளிடு செய்து சரிபார்க்கவும்.

(அல்லது)

(ஆ) கைப்பேசியில் பार्சுகொடு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.

Genuineness of the certificate can be verified by.

(a)Keying in the unique certificate number TN00126TVR49094 in the URL

<https://www.tnsevai.tn.gov.in/edistrict/CheckStatus/Certificate/>

(or)

(b)Reading the 2D barcode with mobile barcode reader and verify through online.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 25, Perumal Vadakku Theru, Madapuram,
Thiruvarur – 610001.

Phone: 04366-221300

E-mail:dwtlthiruvarur@gmail.com



TC – 10751

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2026/25497	Report Issue Date :	01.07.2026	Page No : 01 of 01
Invoice Details:	0164/Dt.20.06. 2026/Amt.Rs.1652/-	ULR No	TC1075126000000328F	

Client Name & Address : The Principal,
Contact No / Email.ID Swami Dayananda Vidyalaya,
Manjakkudi, Thiruvarur.

Sample Name	:	Water			
Sample Number	:	25497			
Sample Description	:	RO Unit			
Sample Submitted by	:	Murugadoss			
Location & Date	:	Inside The Campus & 25.06.2026			
Quantity of sample Received	:	2 Litre			
Sample Container	:	Jerry Cane			
Sample Condition on Receipt	:	Good			
Sample Received On	:	25/06/2026	Environmental Condition	:	23.0°C – 27.0°C
Test Commenced on	:	25/06/2026	Test Completed on	:	01/07/2026

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2019)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25° C	-	IS 3025 Part 11-2022	7	6.5-8.5	6.5-8.5
2	Total Hardness as CaCO ₃	mg/L	IS 3025 Part 21-2009	224	200	600
3	Total Alkalinity as CaCO ₃	mg/L	IS 3025-Part 23-2023	40	200	600
4	Chloride as Cl	mg/L	IS 3025-Part 32-1988	36	250	1000
5	Sulphate as SO ₄	mg/L	IS 3025-Part 24 Sec -01 -2022	26	200	400
6	Nitrate as NO ₃	mg/L	APHA 24th Edition 2023– 4500 –NO3 B	8	45	45
7	Fluoride as F	mg/L	APHA 24th Edition 2023 – 4500- F-D	0.00	1.0	1.5

Remark: The tested sample Conformed to IS: 10500:2012 Drinking water specification with respect to above tested parameters.

.... End of the report....

Authorised Signatory

S.Kathirkamanathan, B.Sc., MBA-Junior Water Analyst

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.
5. Information is provided by the customer, laboratory has not responsible for the sampling stage.


**TAMILNADU WATER SUPPLY AND DRAINAGE BOARD****DISTRICT WATER TESTING LABORATORY****No. 25, Perumal Vadakku Theru, Madapuram, Thiruvapur – 610001.****Phone: 04366-221300****E-mail:dwtlthiruvapur@gmail.com****TEST REPORT**

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2026/25497	Report Issue Date :	01.07.2026	Page 1 of 2
Invoice Details:	0164/Dt.20.06. 2026/Amt.Rs.1652/-			

Client Name & Address Contact No / Email.ID	: The Principal, Swami Dayananda Vidyalaya, Manjakkudi,Thiruvapur.
Sample Name	: Water
Sample Number	: 25497
Sample Description	: RO Unit
Sample Submitted by	: Murugadoss
Location & Date	: Inside The Campus & 25.06.2026
Quantity of sample Received	: 2 Litre
Sample Container	: Jerry Cane
Sample Condition on Receipt	: Good
Sample Received On	: 25/06/2026
Test Commenced on	: 25/06/2026
Test Completed on	: 01/07/2026
Environmental Condition	: 23.0°C – 27.0°C

S. No	Parameters	Test Method	Unit	Result	Specification as per IS 10500: 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Appearance	Visual observation	--	Clear	Clear	Clear
2	Colour	IS 3025 Part 4 - 2022	HU	5	5	15
3	Odour	IS 3025 Part 5: 1983	--	None	Agreeable	Agreeable
4	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	0.5	1	5
5	Total Dissolved Solids	APHA 23rd Edition 2017 – 2540 C	mg/L	193	500	2000
6	Conductivity	APHA 23rd Edition 2017 – 2510 B	µS/cm	276	-	-
7	P - Alkalinity	IS 3025–Part 23-1983	mg/L	0	-	-
8	Calcium as Ca	APHA 23rd Edition 2017 – 3500 Ca B	mg/L	90	70	200
9	Magnesium as Mg	APHA 23rd Edition 2017– 3500 Mg B	mg/L	33	30	100


 Authorised Signatory

S.Kathirkamanathan,B.Sc.,MBA-Junior Water Analyst

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.
5. Information is provided by the customer, laboratory has not responsible for the sampling stage.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 25, Perumal Vadakku Theru, Madapuram, Thiruvavur – 610001.

Phone: 04366-221300

E-mail: dwtlthiruvavur@gmail.com

TEST REPORT


Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2026/25497	Report Issue Date :	01.07.2026	Page 2 of 2
Invoice Details:	0164/Dt.20.06. 2026/Amt.Rs.1652/-			

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
10	Iron as Fe	APHA 23rd Edition 2017– 3500 Fe B	mg/L	0	0.3	1
11	Manganese as Mn	APHA 23rd Edition 2017 – 3500 Mn B	mg/L	0	0.1	0.3
12	Ammonia as NH ₃	APHA 17th Edition-1989– 4500 NH ₃ C	mg/L	0.00	0.5	0.5
13	Nitrite as NO ₂	APHA 23rd Edition 2017– 4500-NO ₂ B	mg/L	0	-	-
14	Total Phosphate as PO ₄	APHA 23rd Edition 2017 – 4500 P- D	mg/L	0	-	-
15	Sodium	APHA 23rd Edition-2017 – 3500Na B	mg/L	27	-	-
16	Pottasium	APHA 23rd Edition 2017– 3500-K B	mg/L	2	-	-
17	Residual Chlorine	IS/APHA	mg/L	1	0.2	1
18	Fecal Coliform	IS/APHA	CFU/ 100ml	0	--	--

Report: The tested sample Conformed to IS: 10500:2012 drinking water specification with respect to above tested parameters.

.....End of the report.....


Authorised Signatory

S.Kathirkamanathan, B.Sc., MBA-Junior Water Analyst

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.
5. Information is provided by the customer, laboratory has not responsible for the sampling stage.